

Policy Review Michigan's 21st Century Energy Plan

August 22, 2006



Michigan's 21st Century Energy Plan

Agenda

- Choosing a Generating Technology
 - Dale E. Heydlauff, American Electric Power Company
 - Jacob Williams, Peabody Energy
- 21st Century Plan Update
 - Resource option information
 - Modeling update




Comparing CNF to 21CEP Modeling for Renewable Energy (2)

| RE Potential (2015 in MW) | CNF Alt-Tech – Scaled-Up | 21CEP |
|------------------------------|-----------------------------|-------|
| Wind | 420 – 443 | 500 |
| LFG | 131 – 138 | 128 |
| Anaerobic Digestion | 51 – 54 | 80 |
| Cellulosic Biomass / CHP | 547 – 576 (CHP/COGEN) | 275 |
| Total | 1149 – 1211 | 983 |




Comparing CNF to 21CEP Modeling for Renewable Energy (3)

Total Renewable Energy by Year as % of System Needs




Michigan's 21st Century Energy Plan

21CEP Renewables Modeled (MW)



21CEP Renewables Modeled (GWh)



Michigan's 21st Century Energy Plan

21CEP Renewable Energy Costs

| System Type | Capital Cost (\$/kW) | Average Cost (¢/kWh) | |
|-------------------------------|----------------------|----------------------|-----------|
| | | 21CEP | CNF |
| Wind | 1,400 | 7.2 | 6.9 |
| Cellulosic Biomass | 2,000 | 7.1 | n/a |
| Swine/Poultry | 2,825 | 8.2 | n/a |
| Dairy | 2,825 | 8.2 | 6.9 |
| Wastewater Treatment Plants | | | |
| Landfill Gas (existing – new) | 1,130 – 1,356 | 7.0 – 7.4 | 6.6 – 6.9 |




Central Station Options

| • Technology | Size (MW) | \$/Kw | Fixed O&M | Variable O&M | Heat Rate |
|----------------------|-----------|-------|-----------|--------------|-----------|
| • Pulverized Coal | | | | | |
| – Sub-critical | 500 | 1,552 | 44.26 | 1.86 | 9,496 |
| – Super-critical | 500 | 1,628 | 44.91 | 1.75 | 8,864 |
| • CFB | 300 | 1,706 | 46.11 | 4.37 | 9,996 |
| • IGCC | 550 | 1,866 | 61.30 | .98 | 9,000 |
| • IGCC – PRB | 550 | 2,090 | 61.30 | .98 | 10,080 |
| • Nuclear | 1,000 | 2,470 | 69.93 | .55 | 10,400 |
| • Combined Cycle | 500 | 529 | 5.57 | 2.19 | 7,200 |
| • Combustion Turbine | 160 | 425 | 2.19 | 3.82 | 10,450 |



21 CEP Energy-Efficiency Modeled (MW) Peak-Hr Reduction




| | | | | | | | | | | |
|-------------------------------|-----|-----|-----|-----|-----|-----|-----|-----|-------|-------|
| Appliance Standards | 21 | 42 | 63 | 84 | 105 | 126 | 147 | 169 | 190 | 211 |
| Load Management (AC-Cycling) | 294 | 331 | 367 | 400 | 431 | 461 | 489 | 517 | 544 | 569 |
| Energy Efficiency Programming | 91 | 182 | 273 | 364 | 455 | 608 | 760 | 913 | 1,065 | 1,218 |

■ Energy Efficiency Programming
 ■ Load Management (AC-Cycling)
 ■ Appliance Standards



Michigan's 21st Century Energy Plan

21 CEP Energy-Efficiency Modeled (gWh) Annual Energy Savings



■ Energy Efficiency Programming
 ■ Load Management (AC-Cycling)
 ■ Appliance Standards



Michigan's 21st Century Energy Plan

Comparing CNF to 21CEP Modeling for EE

| EE Potential (2015) | CNF | 21CEP |
|---------------------------|---------|-------|
| EE Program (gWh) | 4,500 | 8,474 |
| EE Program Peak Red. (MW) | 593 | 1,218 |
| Load Response (MW) | 400-500 | 569 |
| Appliance St. (gWh) | - | 1,231 |



Distributed Technologies

- Stirling Engines
- Reciprocating Engines
- Fuel Cells
- Micro Turbines
- Advanced Storage
- Smart Grid



Reliability Model Stand Alone Results

Standalone (Without transmission ties)

| | BaseCase - CNF | | BaseCase - 21 CEP | |
|------------------|----------------|---------------|-------------------|---------------|
| | LOLP | Support* (MW) | LOLP | Support* (MW) |
| METC | 0.4 | 450 | 0.02 | (-500) |
| ITC | 32.3 | 3840 | 14.58 | 2840 |
| MECS | 5.2 | 3370 | 0.92 | 1160 |
| ATC zone2 | 289.1 | 315 | TBD | |



ITC Region Loss Of Load Probability Results Stand Alone Basis

| Study | Study Year | LOLP - Stand alone | Imports Needed (MW) |
|---------|------------|--------------------|---------------------|
| MTEP 06 | 2006 | 17 | 2,862 |
| CNF | 2009 | 32.3 | 3,840 |
| 21 CEP | 2009 | 14.58 | 2,800 |
| MTEP 06 | 2011 | 28 | 4,600 |



Loss of Load Probability with Transmission Support Assumes 1,500 MW of Flow through Michigan System

IESO Phase Shifter Flow = 1500 MW

| | | | | <u>CNF</u> | | <u>21 CEP</u> | |
|-------------|-----------------------------|--------|-------------|-----------------|--------------------|---------------|--------------------|
| | | | | BaseCase | | | |
| | Imports | Import | Import | | Additional Imports | | Additional Imports |
| Sink | From | Value | Value | LOLP | Needed | LOLP | Needed |
| ITC | MAIN/TVA | 1750 | 1375 | 5.62 | 2080 | 2.3 | 1500 |
| | VACAR/MAAC/ALL | 1500 | 1125 | 7.63 | 2145 | 3.46 | 1700 |
| METC | MAIN/TVA/VACAR/MAAC/ ALL | 1000 | 625 | 0.02 | (-) 560 | 0 | (-960) |
| MECS | MAIN/TVA/VACAR | 1500 | 750 | 1.33 | 1870 | 0.33 | 700 |
| | MAAC/ALL | 1250 | 500 | 1.68 | 1800 | 0.48 | 630 |



Michigan's 21st Century Energy Plan

Loss of Load Probability with Transmission Support Assumes 0 MW of Flow through Michigan System

| | | | | BaseCase CNF | BaseCase 21 CEP | | |
|-------------|---------------|--------|-------------|-----------------|--------------------|-------------|-----------------|
| | Imports | Import | Import | | Add Imports | | Add Imports |
| Sink | From | Value | Value | LOLP | Needed | LOLP | Needed |
| ITC | MAIN | 3000 | 2625 | 0.69 | 880 | 0.2 | 190 |
| | TVA/ALL | 2800 | 2425 | 1.03 | 1050 | 0.3 | 360 |
| | VACAR | 2700 | 2325 | 1.24 | 1100 | 0.37 | 510 |
| | MAAC | 2500 | 2125 | 1.76 | 1350 | 0.57 | 750 |
| METC | MAIN | 3800 | 3425 | 0 | (-) 3360 | N/A | |
| | TVA/ALL | 3500 | 3125 | 0 | (-) 2645 | N/A | |
| | VACAR | 3250 | 2875 | 0 | (-) 3720 | N/A | |
| | MAAC | 3000 | 2625 | 0 | (-) 2530 | N/A | |
| MECS | MAIN | 3250 | 2500 | 0.13 | 120 | 0.01 | (-) 1080 |
| | TVA/VACAR/ALL | 3000 | 2250 | 0.2 | 440 | 0.02 | (-) 800 |
| | MAAC | 2800 | 2050 | 0.28 | 630 | 0.03 | (-) 600 |



Additional Modeling

- Additional Modeling using New Energy's STATGUEST is planned.
- Demand forecast changed from CNF.
- Updated Plant Cost.
- Firmed up Energy Conservation and Renewable estimates.



21st Century Energy Plan

Proposed Integration Scenarios

- Rerun Traditional Scenario with updated data. Sensitivities would include: High/Low Load, and Transmission Reduction.
- Rerun Emissions Scenario with updated data. Sensitivities would include: Full renewable with Conservation, High/Low.
- Rerun Renewable Scenario with updated data and RPS. Sensitivities would include: High/Low Load, and Transmission Reduction.
- Rerun Conservation Scenario with updated data. Sensitivities would include: High/Low Load, and Transmission Reduction.
- Run a Conservation & Renewable Scenario. Sensitivities would include: High/Low Load, and Transmission Reduction.
- Run a Traditional Scenario with only Combustion Turbines. Sensitivities would include: High/Low Load, and Transmission Reduction.



21st Century Energy Plan Proposed Integration Scenarios

| | Traditional Power | Emissions | Energy Conservation | Renewable |
|---|--|--|---|---|
| | Assume Clean Air Interstate Rule and Clean Air Mercury Rule for environmental regulations. | Mercury removal requirements raised to 85% from 1999 baseline emissions in 2018. Carbon tax at \$30 per ton carbon by 2018. | Energy conservation portfolio wired in. | Mandated Renewable Portfolio Standard of 3% by 2008, 5% by 2010 and 7% by 2015. |
| Resource Units | | | | |
| PC Unit | X | X | X | X |
| CT Unit | X | X | X | X |
| GCC Unit | X | X | X | X |
| IGCC Unit | | | X | X |
| IGCC C Seq. | | X | | |
| Nuclear Unit | | X | | X |
| Renewable | | X | | X |
| Energy Conservation | | | X | |
| Sensitivities | | | | |
| High Load | X | X | X | X |
| Low Load | X | X | X | X |
| High Gas Cost | | | | |
| CT only | X | | | |
| Max energy conservation and Renewable | | X | X | X |
| Max Import ¹ | | | | |
| Restricted Import ² | X | X | X | X |
| Assumptions | | | | |
| Normal price driven energy conservation | X | X | X | |
| Carbon tax (\$10.00=2010-\$30.00=2018) ³ | | X | | |
| 85% Mercury Emissions Removal | | X | | |
| IGCC has CO2 sequestering | | X | | |
| Projected energy conservation options | | | X | |
| Renewable Portfolio | | | | X |
| Assumed Transfer Capability(Normal) | 3,000-3,500 | 3,000-3,500 | 3,000-3,500 | 3,000-3,500 |

1) Teir 1 transmission upgrades

2) 1,500 MW transfer to OH

3) Nominal dollars

Contact Information for Policy Issues

- **Central Station:**

Paul Proudfoot, paproud@michigan.gov

- **Renewable & Alternative Energy Options:**

Tom Stanton, tstanton@michigan.gov

- **CHP:**

Steve Kulesia, kulesias@michigan.gov

- **Energy Efficiency:**

Rob Ozar, rgozar@michigan.gov

