

# DTE Energy Smart Grid Projects

**MPSC Smart Grid Collaborative**

**Hawk Asgeirsson**

**Manager – Power Systems Technologies**

**[asgeirssonh@dteenergy.com](mailto:asgeirssonh@dteenergy.com)**

**March 13, 2008**

**DTE Energy®**





# Agenda

- **Defining Smart Grid**
- **AMI Implementation**
- **DG as Distribution Capacity**
- **DG as Virtual Power Plant (DOE)**
- **GridApp Projects (DOE)**
- **PHEV Penetration Study (DOE) – DTE Energy, UofM, PNNL, GM & Ford**



# Defining “Smart Grid”

Electricity delivery network modernized using latest digital/information technologies to meet key defining functions\*

- Enabling active participation by consumers
- Accommodating all generation and storage options
- Enabling new products, services, and markets
- Optimizing assets and operating efficiently
- Anticipating and responding to system disturbances in a self-healing manner
- Operating resiliently against physical and cyber attack
- Providing power quality required by a digital economy

***The evolution of a smart grid will be one of continuous improvement.***

*\* Identified through the Modern Grid Strategy development efforts led by the NETL project team*



# OE Actions on Implementing Title XIII of the Energy Independence and Security Act of 2007

- **Establish a Smart Grid Advisory Committee (By 3/29/2008)**
- **Establish a Smart Grid Task Force (By 3/29/2008)**
- **Submit to Congress a report concerning the status of Smart Grid system deployments (Due 12/19/2008)**
- **Submit to Congress a study assessing laws and regulations affecting siting of privately owned electricity distribution wires on and across public rights-of-way (Due 12/19/2008)**
- **Carry out a program to research, develop, and demonstrate Smart Grid technologies (planned 1<sup>st</sup> Q-FY09 following development of RD&D plan)**
- **Establish a Smart Grid regional demonstration initiative showcasing advanced technologies (planned 1<sup>st</sup> Q-FY09, guided by RD&D plan)**
- **Establish a federal matching funds program (By 12/29/2008)**
- **Submit to Congress a quantitative assessment concerning the security implications of Smart Grid system deployments (Due 6/19/2009)**



# Smart Grid Task Force

## Functions

- Serves as Federal focal point on all things “smart grid”
- Coordinates and integrates intra- and inter-governmental activities
- Oversees report production for submission to Congress
- Oversees development of smart grid RD&D plan
- Guides smart grid regional demonstrations
- Advises on interoperability framework
- Guides establishment of the federal matching funds program
- Develops tech assistance plan to States and guides plan implementation
- Guides outreach and communications to build awareness and educate decision makers
- Collaborates with and supports FACA

## Members

- OE:** leadership, RD&D, policy analysis, infrastructure protection
- FERC:** wholesale markets
- NIST:** interoperability standards
- EERE:** energy efficiency and renewables
- DHS:** homeland security
- DoD:** national security
- EPA:** climate change



# Smart Grid Implementation Workshop

Planned for June 2008, with broad stakeholder engagement to reach consensus on and acceptance of:

- Key defining functions or “characteristics” of a smart grid
- Values associated with a smart grid
- Metrics for measuring progress toward a smart grid



## Input to:


- Smart Grid RD&D Plan development
- Soliciting and selecting smart grid regional demo activities

**A Planning Committee comprising a broad representation of smart grid stakeholders is organizing the Workshop.**



# Interoperability Framework Development

## GridWise Architecture Council (GWAC)



Framework Areas



# Tech Assistance to States

- Modern Grid Strategy team working with State Regulators to formulate State strategies for modernization
  - Promoting deployment of smart grid technologies
  - Focus on business case model
  - Providing feedback into State program direction and performance
  - Suggesting regulatory action to address barrier
  - Supporting, and supported by, WV and OH regulators



## **Input to:**

Tech assistance plan to support States in developing and implementing smart grid pathways



# Communications and Outreach for Public Awareness

## National GridWeek 2007, April 2007 in DC

- Aligning and coordinating national agenda on grid modernization
- 634 participants, including federal/state/industry/Lab leaders
- Inaugural event organized and sponsored by OE



## National GridWeek 2008, September 2008 in DC


- GridWise Alliance as Lead Organizer; OE as major sponsor
- Becoming *the* national event on smart grid
  - technologies and practices
  - policies and regulations
  - lessons learned and success stories
  - business cases
  - education and outreach

### Smart Grid Newsletter

Monthly publication covering news, trends, research and marketplace information relevant to grid automation (<http://www.smartgridnews.com/>)



# Overview of primary AMR / AMI technologies




\* Remote disconnect/ reconnect capabilities are available on RF and PLC network options and are not available with a mobile network



# AMI – a platform to build on

## Advanced Metering Infrastructure



# Numerous Legacy Systems at DTE Energy are affected With MDM serving AMI





Regulated Mass Market



Electric Choice



Regulated C&I Service




Legacy systems will be updated  
Sequentially over time

# Agenda

- **AMI Implementation**
- **DG as Distribution Capacity**
- **DG as Virtual Power Plant (DOE)**
- **GridApp Projects (DOE)**
- **PHEV Penetration Study (DOE) – DTE Energy, UofM, PNNL, GM & Ford**



# DTE Energy Service Area



*Utility Service Territory*



**Service Area: 7,600 Sq. Miles**

**Customers: 2.2 million**

**System Peak Load: 12,762 MW**

**Annual Sales: 54,000 GWH**

**37% Commercial**

**29% Residential**

**29% Industrial**

**5% Wholesale & Interconnection**

**Distribution Substations                      662**

**Distribution Circuits                              2,808**

**1,876 @ 4.8kV**

**932 @ 13.2kV**

**Distribution Circuit Miles                      38,939**

**20,184 @ 4.8kV**

**18,755 @ 13.2kV**

**Subtransmission                              802 @ 24 kV**

**2,743 @ 41.6kV**



# DG Distribution Solutions


## DG Circuit Installations

12 Different Installations

6 Operating DGs in 2007

2 New Installations in 2008

Intentional Islanding 4 times



*Utility Service Territory*



Detroit Edison



MichCon




Overlap





# Asset Utilization Opportunity

**Pioneer DC 9796**  
 Percent Load vs. Percentage of the Year



# Internal to Distribution Circuit



# Substation Applications



# Peak Shaving Application

**Problem:**  
Transformer  
Or Circuit  
Overloading

Circuit Load


**Solution:**  
Line Support Using Distributed  
Energy Resource(s)



Transformer



Circuit Load  
Current



Site Controller

Generator Data

Control Data:  
• Start/Stop  
• Output Level



Distributed Energy Resource

# Automatic Load Following




Grosse Ile 7-13-2005 Multi-Point Trend report

Report date:

Report span:

Total days:





# Past & Present DG Run Hours

Circuit	D-D Rating	Peak Rating	2004 Run Hrs	2005 Run Hrs	2006 Run Hrs	2007 Run Hrs
IVNHO	600 A	721 A	N/A	N/A	96	102
GOLF	406 A	630 A	N/A	N/A	64	59
UNLAK	601 A	746 A	188	410	Retired	Retired
GRILE	490 A	553 A	40	234	31	122
SHORES	493 A	553 A	41	122	82.5	35
MILFD	590A	726 A	32	58	12	55
WEBST	360 A	505 A	N/A	75	4	0
90+ Degree Days	N/A	N/A	3	20	12	14

**On-Board  
Communication mast**

**1.5 MW, 4800V, 3ph, Direct Connect  
Bi-Fueled Generator**

**Underground or overhead house  
service**

**External  
Fuel Fill**



**Fence Free Design**

**Bi-Fuel  
Design for  
extended  
run time**

# Agenda

- **AMI Implementation**
- **DG as Distribution Capacity**
- **DG as Virtual Power Plant (DOE)**
- **GridApp Projects (DOE)**
- **PHEV Penetration Study (DOE) – DTE Energy, UofM, PNNL, GM & Ford**



# DOE Phase 1 & 2




## Department of Energy DER Aggregation Communication, Control, and MISO Sale





# Detroit Edison Service Area



*Utility Service Territory*

- Detroit Edison
- MichCon
- Overlap

**Customers: 2.2 million**

**System Peak Load: 12,762 MW**

**Annual Sales: 56,000 GWH**

**37% Commercial**

**29% Residential**

**29% Industrial**

**5% Wholesale & Interconnection**

**Distributed Generation: 1.6 GW  
or 12 % of Peak Load  
(Includes > 100kW units)**

**Primary Service Database** (approx unverified)


**500kW > DG > 100kW**                      **50MW**

**20MW > DG > 500kW**                      **590MW**

# Communication Architecture in place from DOE 2 (No human intervention required)



## Utility – Aggregator Business Model






# DEW Modeling For DOE 2


## Constraints

DG needed for Demand Management  
 Customer Hours DG not available  
 Total run hours not to exceed e.g. diesel air permit limits  
 Circuit Level Restrictions



DEW is a Freeware using open architecture database. All functionally developed in this project will be included in DEW.

# Communication Architecture Aggregating for Day Ahead



# PI Process Book General Display

# Real Time

# Day Ahead

5/16/2006 11:23:16 AM

**COMMUNICATION LINK**

DTE SOC   

DTECH   

**Total Generation**

KW

**Circuit Avg. Load**

Amps

**DG Status Legend**

- OFF

- ON

- BAD STATE

**DEW Suggested Action**

KW      KVAR

**Participating Legend**

- NOT PARTICIPATING

- PARTICIPATING

- BAD STATE

Site #	CIRCUIT NAME - GENERATOR
1	ANGOLA DC8862 - Lawrence Tech. U. 150+150KW NG
2	BROOKS DC8081 - Meadowbrook Insurance 800KW D.
3	CRESTWOOD DC8307 - S.Y.Systems 500KW Diesel
4	DUVALL DC9455 - Karmann Manufacturing 1000KW D.

Total Generation	Circuit Avg. Load	DG Status	DEW Suggested Action	Participating In Market
300 KW	263 Amps	<span style="color: red;">●</span> <span style="color: red;">●</span> 0 KW	0 KW    0 KVAR	<span style="color: red;">●</span> 0 KW
800 KW	204 Amps	<span style="color: red;">●</span> 0 KW	0 KW    0 KVAR	<span style="color: red;">●</span> 0 KW
500 KW	252 Amps	<span style="color: cyan;">●</span> 0 KW	0 KW    0 KVAR	<span style="color: red;">●</span> 0 KW
1000 KW	119 Amps	<span style="color: red;">●</span> 0 KW	0 KW    0 KVAR	<span style="color: red;">●</span> 0 KW

5	EMERICK DC2925 - Washtenaw County Bldg4 255KW
6	FARMINGTON DC8892 - Botsford 150KW Nat Gas
7	FISHER DC8188 - ASC Global 2000KW Diesel
8	FISHER DC8188 - Flat Rock Comm.Center. 500KW
9	FRISBIE DC2125 - Metropolitan Baking 600KW D
10	<b>GOLF DC8518 - 2MW Diesel Generator</b>
11	GROSSE ILE DC 2841 - Grosse Ile Schools 1MW
12	<b>VAHNOE DC1760 - 1.5.MW Bi-fuel Generator</b>
13	JOSLYN DC9182 - Alps Automotive 500KW Diesel
14	MEDINA DC8533 - Adell Comm. 600KW Diesel
15	MILFORD DC8103 - Milford Junction-MCN 1MW NG
16	PIONEER DC8793 - Warde Labs 600KW Diesel
17	SHELDON DC9508 - Arctic Cold Storage 750KW
18	SHORES DC1770 - Greek Orthodox Church 1MW
19	SOUTHFIELD DC9010 - Southfield 26KW Solar + 50KW
20	SPRUCE DC9874 - Washtenaw County Bldg3 200KW
21	SUNSET DC9016 - Farmington 85KW Nat Gas
22	TIENKEN DC8850 - Beaumont Dialysis 150+150 N.G.
23	<b>UNION LAKE DC1688 - Union Lake 2MW Diesel</b>
24	Webster DC371 - 500 KW Diesel

	UNIT 1	UNIT 2	
ACT.	ACT.	ACT.	REC.
X AMPS	0	0	
Y AMPS	0	0	
Z AMPS	0	0	
TOTAL KW	0	0	Pt Created
TOTAL KVAR	0	0	Pt Created
TOTAL KVA	0	0	
TOTAL PF	1.00	1.00	
X-Y Volts	0	0	
Y-Z Volts	0	0	
Z-X Volts	0	0	

**DG 1    DG 2**

DG's Current

DG's Voltage

DG's Total KW

DG's Total KVAR

Contacts and SOP

Enable Control

Check if Procedure has been followed


Communication Link

DTE SOC   

DTECH   

## Beaumont Dialysis

### Tienken DC 8850



Override Setting 150    Current Status ●    Current Status ●    Override Setting 150

OFF    ON    OFF    ON

●    ●    ●    ●

Status

Circuit phase currents

Circuit phase voltages

**Total Generation 18,216 KW**

# DOE Phase 3 – System Study DER Advanced Integration



**Rolls-Royce Fuel Cell System**






# DOE 3 Project Phases

## Three Phases

- **System Study**
  - **Build Entire Detroit Edison Electrical System**
  - **Customer DER Survey**
  - **Quantifying the benefits of Customer DG on the electrical system for various levels of integration**
    - **Loss reduction & released capacity**
  - **Economic Analysis of Customer DG**
  - **System Reliability Analysis with Customer DG**
  - **Penetration Limits**
- **Development of 1 MW Inverter and fuel cell system at NextEnergy**
- **Intentional Islanding**
  - **Microgrid Demonstration**
  - **Circuit level Demonstration**
  - **System Islanding Study**

# Virtual Power Plant – Dispatchable Customer Generation Program



*Utility Service Territory*



- Create a 300 MW Virtual Power Plant over the next 10 years using customer generation
- Approximately 200 customers
- 20 MW in 2008
- 30 MW/year beginning in 2009
- Low cost peaking plant
- Provide maintenance, fuel cost, paralleling switchgear and monitoring



# Total System Study

## Potential Cost for various levels of DER integration

<u>Level of Integration</u>	<u>KW Benefit</u>	<u>Cost Range</u>
• Just interruptible	Min-Max Load offset	\$ 0
• Standby with soft transfer (nicer for customer)	Min-Max Load offset	\$ 0 - 75,000
• Parallel sellback (no transfer trip)	Sell back maybe limited	\$ 0 - 125,000
• Parallel sellback (with installed transfer trip)	Max Sell back	\$ 150,000+
• <b>Cost measures</b>		
– Cost per capacity added		
– Energy cost per hour		
– <b>Additional Environmental Cost per customer will be analyzed</b>		

\* Cost does not include distribution system upgrades that maybe required

# Agenda

- **AMI Implementation**
- **DG as Distribution Capacity**
- **DG as Virtual Power Plant (DOE)**
- **GridApp Projects (DOE)**
- **PHEV Penetration Study (DOE) – DTE Energy, UofM, PNNL, GM & Ford**



# GridApp Consortium

- **The Advanced Grid Applications Consortium (GridApp) is a consortium of utilities that join together to help modernize the U.S. electrical grid**
- **GridApp provides a fast-track process for engineering development, demonstration, and validation of selected High-Impact Technologies. Our mission is to transition best technologies and best practices into broader use by member utilities.**



# GridApps Technology Testing



Trip Save 1 shot Recloser in a cutout



GridSense LineTracker communicating meter Load and fault current



Kyle Retrofit Communicates load & fault current



Cooper Cap Control with neutral sensing



Substation in a box



Figure 1. Kyle® Type NOVA-TS Triple-Single, Electronically Controlled Recloser Microprocessor-Based Recloser Control.

Cooper Triple Single



Autonomous Storm Detector interactively modifying relay trip settings



Radio Communicating Fault Indicators



# GridApp Consortium

- **Completed Projects**
  - **Autonomous Storm Detector (ASD)- FirstEnergy**
  - **Distribution Center (DC) In a Box - Exelon**
  - **Synchronized Measurement Analysis in Real Time – SCE**
  - **GenOnSys Phase I - Portland General Electric**
- **Projects In Process**
  - **Advanced Capacitor Control System (ACCS) - Idaho Power**
  - **S&C TripSaver – DTE Energy**
  - **Dispatchable Energy Storage System - First Energy**
  - **Distribution Coordinated Control - DTE Energy**
  - **GenOnSys Phase II - Portland General Electric**
  - **GridSense LineTracker DataPAC Development – CTC/DTE/SCE**
  - **Substation Engineering Modeling Tool (SEMT) – SCE**
  - **Radio Communicating Fault Indicators – Exelon**



# S&C TripSaver™ Project Overview

- **Receive ten (10) S&C TripSaver™ Dropout Recloser trial units from S&C.**
- **Perform electrical testing at the Warren Service Center high voltage test laboratory.**
- **Perform physical testing and handling at the Pontiac Service Center overhead lines test yard.**
- **Install six (6) trial units at locations on Wolfhill DC 8822 and Wolfhill DC 8838.**
- **Monitor the performance of the TripSaver™ using Gridsense™ LineTrackers with remote communication.**
- **Provide feedback to the GridApp™ Consortium and S&C.**



# S&C TripSaver™ Dropout Recloser

- **Advantages of Using the S&C TripSaver™ Dropout Recloser**
  - **Improve the reliability of the electrical distribution system.**
  - **Ideal for long, heavily wooded single-phase laterals.**
  - **Reduce the number of customers affected by momentary outages using the traditional “fuse saving” methods. (i.e. fast curve on a recloser)**
  - **Reduce fuse blowing caused by temporary faults.**



# S&C TripSaver™ – Operating Sequence

- **Operating Sequence Open - 5s – Close – Open - Dropout**
- **After Dropout, 5 seconds - Close contacts (Resets)**
- **Lineperson now manually closes TripSaver**


**TripSaver Closed**



**TripSaver Dropped Out**



# GridSense Line Tracker – Develop DNP Radio Communication



## 1. LineTracker Sensing & Detection

- Automatic Adaptive Event Recording
  - Fault Current
  - Protection Operation
  - Outages & Restorations
- Load Profiling from 1 – 60 minute averages


## 2. Onsite Wireless Communications

- LT-DataLink transceiver and LineMan software provide wireless:
  - Device Configuration
  - Data Download
  - Device upgrades

## 3. Installations


- Behind essential fuses
- Poor performing pockets
- Areas needing more model accuracy

# Milford Coordinated Control Project (Model-Base Hieratical Control)














# Milford Coordinated Control Project (Model-Base Hieratical Control)





# Model-based, Hierarchical Control Coordinated Control All Algorithms



-  Sub LTC
  -  New Line Recloser
  -  Line Fuse
  -  Switched Cap
-  Customer Outage Call
  -  Older Line Recloser
  -  GridSense Load & Fault Recorder
  -  Vreg

# Coordinated Control Optimization Algorithms



- **Capacity Constrained (only a few hours per year)**
  - **Mission is to Resolve the capacity shortfall regardless of losses**
  - **DG has air permit has max number of hours as a constraint**
- **System Normal (most of the year)**
  - **Mission is to minimize losses**
  - **Max number of switching operations is a constraint**
  - **Fail safe default setting for loss of communication**
- **Abnormal System (shutdowns and outages)**
  - **Capacity Constrained**
  - **Non Capacity Constrained**

**DEW's Coordinated Control has two modes of operation:**

- **Real time control of all active devices**
- **Planning Mode used to justify retrofitting legacy devices &/or targeting the adding of new devices and control**

# Coordinated Control



## **Control – Overload, Voltage, Reactive, Losses**

- **DG** – Existing DG Operation & Control updated
  - Recloser switched between 3-phase and 1-phase
  - Defaults - Recloser will be 3-phase upon loss of communication
- **Cap Control** – Modify existing cap controls
  - Phase voltage and neutral current sensing
  - Defaults - Voltage over ride (normal range)
  - Cap tag out procedure tied to neutral current
- **Voltage Control** – Modify existing fixed voltage control
  - Defaults - Voltage over rides (normal range)
- **Merge Controls** – Combine all of the above into a coordinated control

**Monitored Data** – used to validate model, assure control has been implemented enabling further control, detect configuration change and fault identification & location

## **Configuration Changes**

- **Normal Configuration changes** – Model updated and Sensitivity Matrix recalculated
- **Outage Identification & Fault Location** – Merge GridSense, recloser, and substation relay fault data with outage calls from Outage Management System



# Coordinated Control - Fault Location

Possible fault location using DEW V7 Google Interface



Wooded, possible interference



# Agenda

- **AMI Implementation**
- **DG as Distribution Capacity**
- **DG as Virtual Power Plant (DOE)**
- **GridApp Projects (DOE)**
- **PHEV Penetration Study (DOE) – DTE Energy, UofM, PNNL, GM & Ford**




# PHEV Study

- **Task 1. Technological Barriers to Acceptable PHEV Performance and Cost**
- **Task 2. Consumer Attitudes and Behavior regarding Adoption of the PHEV**
- **Task 3. Impact of PHEVs on the Reliability of the Electric Grid**
- **Task 4. Impacts Assessments on the transmission and distribution system**
- **Task 5. Integrated analysis of PHEV on the future U.S. energy system**
- **Task 6. Impacts on the wholesale power markets**




# What Impact Would Uncontrolled Charging Have on the Overall Electric Grid?


Uncontrolled Charging Profile – 10% Plug-in Penetration\*



DTE Summer Peak Load with 10% Plug-in Penetration\*





DTE Winter Weekday Load with 10% Plug-in Penetration\*



\* Assumes all vehicles arrive home between 3 and 9pm and that arrival times are normally distributed



# Uncontrolled Charging Would Lead to Localized Distribution Disruptions



- Transformers are rated to handle peak loads of approximately 140% design load (e.g., 70 kW for a 50 kVA transformer)
- Peak loads in excess of 140% or extended periods of time at peak loading can lead to localized electric service problems
  - Voltage dips (dimming lights, damage to expensive electronics)
  - Service interruption
  - Transformer failure
- Multiple vehicles charging on one transformer, even at relatively low charge rates, can lead to electric service problems/disruptions
- Measures can be taken to mitigate potential grid issues
  - On-vehicle charging control (time/date control)
  - Circuit inspection/troubleshooting by local utility as part of purchase process
  - SmartGrid technology will allow virtual real-time charging management and transformer troubleshooting

\* Load shape for warm summer day. 6-10 homes per 50 kVA circuits in newer neighborhoods. 100% central AC penetration assumed. Current DTE planning standard.

\*\* Load shape for warm summer day. 8-12 smaller, older homes per 25 kVA circuit. Most homes without central AC.



# Questions

